



DRINKING WATER QUALITY REPORT for 2025

Tri City Water & Sanitary Authority is pleased to present you with the Annual Water Quality Report for 2025. This report gives you a brief look at the quality of your drinking water.

Our goal is to provide you with a safe and dependable supply of drinking water. We want to help you understand the efforts we make to continually improve the water treatment process and to protect our water resources.

Our water source is surface water, taken from the South Umpqua River. Surface water refers to water that comes from an above ground source, such as a lake, river, stream, or reservoir.

The Environmental Protection Agency (EPA) establishes drinking water standards based on possible health effects that could result from exposure to a wide variety of substances, along with specific testing schedules for these substances.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline 800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material. It can also pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants. To ensure that tap water is safe, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen their risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Tri City Water is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running a tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an ANSI accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested contact Tri City Water at 541.863.5276. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

EPA's 2021 Lead and Copper Rule Revisions (LCRR) required public utilities to inventory water service lines and notify people served by potential or know lead service lines. Tri City Water has completed the inventory, and no lead service lines were found or suspected. The service line inventory can be found at <https://yourwater.oregon.gov/leadcopper.php?pwsno=00549>

A Source Water Assessment has been completed by the Oregon Department of Environmental Quality to identify the surface and subsurface areas that supply water to Tri City's water system intake. Potential contaminant sources identified include areas with high soil permeability, erosion and runoff potential within 1,000 feet of the river/streams. A copy is available upon request at our office or from Oregon DHS/DWP.

Violations – There were no violations in 2025.

You are invited to attend regularly scheduled Board of Directors' meetings on the second Wednesday of each month at 6:30 p.m. at our office, 215 N. Old Pacific Hwy. For more information, call (541)863-5276.

Statistics:

Connections: Approximately 1,700 which includes larger meters that serve multi-unit housing such as mobile home parks, apartment complexes, as well as schools, churches, business, commercial, and industrial.

Service Area: 1952 acres or over 3 square miles.

For more information, please contact Paul Wilborn, Manager or Brian Kelly, Treatment Plant Operator at (541)863-5276

This institution is an equal opportunity provider and employer.

TRI CITY WATER & SANITARY AUTHORITY WATER QUALITY REPORT FOR 2025

All public water systems in Oregon, no matter what their size, must comply with State monitoring regulations and meet safe drinking water standards. Tri City Water and Sanitary Authority routinely monitors numerous constituents in your drinking water according to Federal and State laws. To simplify the Consumer Confidence Report, the Oregon State Health Department requests that only certain contaminants be listed. The table in this brochure shows the results of our monitoring for the period January 1 to December 31, 2025. The table below indicates terms and abbreviations with which you may not be familiar. To help you better understand these terms we've provided the following definitions and examples.

ND – not detectable

Parts per billion (ppb) or Micrograms per liter (ug/L) – One part per billion is roughly equivalent to one sheet in a roll of toilet paper stretching from New York to London.

Nephelometric Turbidity Unit (NTU) – Nephelometric turbidity unit is a measure of the clarity of water. Turbidity describes how cloudy the water is; the smaller the number, the clearer the water. Turbidity has no health effects; however, it can interfere with disinfection and provide a medium for microbial growth.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial growth.

To keep drinking water pure after it leaves the treatment plant, Tri City Water & Sanitary Authority maintains a **CROSS CONNECTION CONTROL PROGRAM** as required by the Oregon Department of Human Services Drinking Water Program. A cross connection is an actual or potential connection with Tri City's potable water and another water source or any contaminant or pollutant. Water can flow backward from a water user into the public supply under pressure or by back siphonage when water pressure in the main lines is reduced. When a cross connection risk is found, the owner is asked to install the proper backflow assembly. Examples of a risk would be underground sprinklers, pools, hot tubs, wells, etc. If you would like to know if your home or business is free of cross-connections, please call our specialist at (541)863-5276 for a free safety survey.

We are proud that your drinking water meets or exceeds all Federal and State requirements. For additional testing results and information please visit www.yourwater.oregon.gov

TREATED WATER TEST RESULTS 1/1/25 TO 12/31/25

CONTAMINANT	VIOLATION Y/N	LEVEL DETECTED	UNIT MEASUREMENT	MCLG	MCL	LIKELY SOURCE
Turbidity						
Turbidity	No	Min 0.024 Max 0.220 Ave 0.039	NTU	NA		Soil runoff & stream sediment
Inorganic Chemicals - The most recent required test was completed on 1/30/20						
Sodium	No	4750	ppb	20,000	20,000	Erosion of natural deposits
Volatile Organics – The most recent required test was completed on 05/05/25						
Bromodichloromethane	No	0.9	ppb	unregulated		Disinfection byproduct
Chloroform	No	5.3	ppb	unregulated		Disinfection byproduct
Dichloromethane	No	17.2	Ppb	unregulated	5 ppb	Disinfection byproduct
Disinfection By-Products – Range and Highest Local Annual Average						
Trihalomethanes	No	5.5 – 29.7 LRA-17.6	ppb	0	80	By-product of drinking water disinfection.
Halocetic Acid	No	5.2 – 10.5 LRA-8.4	ppb	0	60	By-product of drinking water disinfection.
Chlorine Residual	No	0.72 - 1.67 Average-1.20	ppm	(MRDLG) 4.0	(MRDL) 4.0	Added during treatment process for disinfection
Lead and Copper - The most recent required testing was done on 9/16/25						
Copper*	No	76*	ppb	1300	AL 1350 ppb	Corrosion of household plumbing systems
Lead *	No	2*	ppb	0	AL 15 ppb	Corrosion of household plumbing systems

*This value is the required 90th percentile value from the most recent sampling. No Lead & Copper testing sites exceeded the action level for amount of contaminant.

Water testing is performed by: **Umpqua Research Co. of Myrtle Creek.**
Please visit our website at www.tcwsa.com.